



August 25, 2019

RE: Rowan University, Wilson Hall Dance Program Expansion
Addendum 1 Narrative

Please accept this letter as part of Addendum 1 for clarity regarding Division 27 which is not referenced in the technical sections of the Wilson Hall Dance Program Expansion Project Manual.

1.1 Clarification #1: Data Connections

Rowan University maintains an on-call contractor who will be responsible for the following and therefore be excluded from the final bid:

- Installation of station and backbone cabling
- Terminations
- Testing

The electrical contractor is responsible for the following and the work shall be included in the final bid:

- All pathways including conduit, pull string and back box shall be the responsibility of the electrical contractor.

1.2 Clarification #2: Demountable Partitions

Office front demountable partitions at Office 111, 112, 113, and 114 and associate Doors 111, 1112, 113, 114 to be provided by Owner's Furniture Manufacturer Corbett. Contractor is responsible for coordination of demountable partition system with building systems.

1.3 Clarification #3: Specification 230900 HVAC Instrumentation and Controls

See attached Specification 2309000 HVAC Instrumentation and Controls for changes to HVAC Instrumentation and Controls.

Addendum 1 Attachments:

- Answer to Question 46
- Answer to Question 63
- A701 Clarification to Question 5
- S003 Clarification to Question 5
- Wilson Hall Floor Plans – Issue for Reference Only

Sincerely,

Alexis Breining - Project Manager
Department of Design and Construction
Facilities Operations & Planning