

ADDENDUM #3 & ACKNOWLEDGEMENT

To: All Vendors
Date: September 8, 2020

Changes to Specifications

#	Item	Description
1	Questions & Answers	Questions & Answers (Second Set) have been posted as part of this Addendum.

The information contained herein revises, supplements and/or supersedes the specific parts of the documents referred to and shall be attached to and become part of those documents as if originally forming a part thereof. Except herein as modified, all other provisions of the documents shall remain in full force and, unless otherwise described in this Addendum, shall comply with the requirements originally specified. All other conditions of this project will remain in effect.

- Office of Contracting & Procurement website: <https://sites.rowan.edu/procurement/bids/index.html>
- Please direct any questions to bids@rowan.edu

ADDENDUM ACKNOWLEDGEMENT

I acknowledge that I have received and reviewed this Addendum

Company Name (please print)

Name (please print)

Signature

Date

THIS ACKNOWLEDGEMENT IS REQUIRED WITH SUBMISSION

Questions & Answers

	1	Question & Answer
		Please provide the existing building fire alarm vendor.
		Franklin Alarm.

	2	Question & Answer
		Please provide the existing building HVAC controls vendor.
		Honeywell.

	3	Question & Answer
		Please confirm this is a prevailing wage project?
		Yes. Please see the section titled, "Prevailing Wage Act," on page 17 of the IFB Document.

	4	Question & Answer
		Please verify if we are to include teledata work in our proposal or if this will be done by owner.
		Teledata is by Owner.

	5	Question & Answer
		Please provide detail for the piece of equipment the new condensate is being attached to?
		Condensate line ties into a chiller associated with the NMR unit be installed in the space by a 3rd party vendor.

If you submitted questions to bids@rowan.edu by the due date indicated in the RFP document, but they were not received and answered here, please contact:

Robert Yufer
Office of Contracting & Procurement
Yufer@rowan.edu
856.256.4196